CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7320-0026:246 Page 1 of 1

CATEGORY: Speakers

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001

Contact: Paul D. Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN: Models 4903-9148, -9149, -9150, -9150H, -9153, -9193, -9194, and -9195

speaker/strobes. Refer to listee's data sheet for detailed product description and

operational considerations.

RATING: 25 or 70 V rms, 1/4, 1/2, 1 and 2 Wattage Taps

-9150, -9150H, -9153: 15cd

-9148, -9194: 30cd -9149, -9195: 110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number electrical rating and UL label.

APPROVAL: Listed as hearing impaired speaker/strobes for use with separately listed fire alarm control

units. Models with a suffix "H" is intended for indoor humidity of up to 95%. All versions

are intended for indoor use only.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to

manufacturer's Installation Manual for details.

*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 17, 2004 Listing Expires June 30, 2005

Authorized By: DIANE K. AREND, Senior Deputy

Program Manager